



Infilco

Proven.



HEADWORKS
BIOLOGY
SEPARATION
MEMBRANE
DISINFECTION
BIOSOLIDS
SYSTEMS

Thermylis High Temperature Fluid Bed Installation List

2008

Duffin Creek WWTP Region of Durham, ON, Canada

Peter Burrowes
(519) 579-3501

Reactor I, II
Feed Rate:

Sludge Characteristics
Heat Recovery
Air Pollution Control System
Startup:

Each reactor:
32'-1" ID, hot windbox design
9,645 lb/hr dry solids, sewage sludge
90.4 MM btu/Hr
28%TS, 68%VS, 10,007 btu/lbVS
Waste heat boiler, 508 psig steam
Venturi scrubber
2009

Mill Creek WWTP Cincinnati, OH Biju George (513) 368-1429

Reactor: I, II, III
Feed Rate:

Sludge Characteristics
Air Pollution Control System
Startup:

Each Reactor:
26'-6" ID, hot windbox design
8,000 lb/hr dry solids, sewage sludge
76.4 MM btu/Hr
26%TS, 70%VS, 10,500 btu/lbVS
Venturi Scrubber
2009

Lakeview WWTP, Phase II Mississauga, ON, Canada William Fernandes 905/791-7800, Ext. 4413

Reactor: I, II, III
Feed Rate:

Sludge Characteristics
Air Pollution Control System
Startup:

Each Reactor:
30'-6" ID, hot windbox design
9,200 lb/hr dry solids, sewage sludge
89 MM btu/Hr
27%TS, 75%VS, 9,607 btu/lbVS
Venturi Scrubber
2007, 2008

R.L. Sutton WWTP

Cobb County, GA

Mr. Bob Szoch

404/495-8700

Reactor I, II

Feed Rate:

Sludge Characteristics

Air Pollution Control System

Startup:

Each Reactor:

22'-0" ID, hot windbox design

4,400 lb/hr dry solids, sewage sludge

48 MM btu/Hr

25%TS, 75.5%VS, 10,000 btu/lbVS

Venturi Scrubber

October 2007

Lakeview WWTP, Phase I

Mississauga, ON, Canada

William Fernandes

905/791-7800, Ext. 4413

Reactor:

Feed Rate:

Sludge Characteristics

Air Pollution Control System

Startup:

30'-6" ID, hot windbox design

9,200 lb/hr dry solids, sewage sludge

89 MM btu/Hr

27%TS, 75%VS, 9,607 btu/lbVS

Venturi Scrubber

February 2006

Ypsilanti CUA

Ypsilanti, MI

Ken Knorp

734/484-4600, Ext. 142

Reactor:

Feed Rate:

Sludge Characteristics

Air Pollution Control System

Startup:

24'-0" ID, hot windbox design

6,300 lb/hr dry solids, sewage sludge

65 MM btu/Hr

25%TS, 76.5%VS, 10,000 btu/lbVS

Venturi Scrubber, Wet ESP and

Activated Carbon Adsorber

December 2005

Puerto Nuevo

San Juan, Puerto Rico

Manuel Rosabal

787/758-4040

Reactor:

Feed Rate:

Sludge Characteristics

Air Pollution Control System

Startup:

24'-0" ID, hot windbox design

5,325 lb/hr dry solids, sewage sludge

55 MM btu/Hr

29%TS, 70%VS, 10,000 btu/lbVS

Venturi Scrubber, Wet ESP

January 2004

City of Valence

Valence, France

Gerard Rondeau

33 1 46 25 62 95

Reactor:	13'-6" ID, hot windbox design
Feed Rate:	1,142 lb/h dry solids, sludge & Skimmings
Sludge Characteristics	16 MM btu/Hr
Air Pollution Control System	20%TS, 67%VS, 10,350 btu/lbVS
Startup:	Bagfilter, Chemical Injection
	September 2003

District d'Elbeuf

Normandy, France

Jacques Thoraval

33 32 96 98 98

Reactor:	11'-6" ID, hot windbox design
Feed Rate:	952 lb/h dry solids, sewage sludge
Sludge Characteristics	13 MM btu/Hr
Air Pollution Control System	21%TS, 66%VS, 9,691 btu/lbVS
Startup:	Bagfilter, Chemical Injection
	July 2003

Metropolitan Sewer

District of Cincinnati, Ohio

Mike Heitz

513/244-5137

Reactor:	24'-0" ID, hot windbox design
Feed Rate:	6,000 lb/hr dry solids, sewage sludge
Sludge Characteristics	63 MM btu/Hr
Air Pollution Control System	25%TS, 70%VS, 10,000 btu/lbVS
Startup:	Venturi Scrubber
	November 1999

Northwest Bergen County

Utilities Authority, Waldwick, New Jersey

Jack Myer

201/447-2600

Reactor:	16'-0" ID, hot windbox design
Feed Rate:	2,200 lb/hr dry solids, sewage sludge
Sludge Characteristics	26 MM btu/hr
Air Pollution Control System	23%TS, 78%VS, 10,000 btu/lbVS
Startup:	Venturi Scrubber, Wet ESP
	August 1999

**Camden County Municipal
Utilities Authority, Blackwood, New Jersey**

**Jack Connelly
856/541-3700**

Reactor:	9'-0" ID, hot windbox design - rebuild
Feed Rate:	816 lb/hr dry solids, sewage sludge
Sludge Characteristics	8 MM btu/hr
Air Pollution Control System	24%TS, 76%VS, 10,000 btu/lbVS
Startup:	Venturi Scrubber
	September 1996

**TZ Osborne WTP
Greensboro, North Carolina**

**Arthur White
336/375-2240, Ext. 224**

Reactor:	20'-0" ID, hot windbox design
Feed Rate:	5,000 lb/hr dry solids, sewage sludge
Sludge Characteristics	50 MM btu/hr
Air Pollution Control System	28%TS, 70%VS, 10,000 btu/lbVS
Startup:	Venturi Scrubber
	June 1996

**Morton International
Moss Point, Mississippi**

**Mark Eckman
601/474-4248**

Reactor:	20'-0" ID, hot windbox design
Feed Rate:	6,300 lbDS/hr, syn. rubber waste
Sludge Characteristics	50 MM btu/hr
Air Pollution Control System	70%TS, about 50%VS, HHV unknown
Waste Heat Boiler	Bagfilter, Scrubber
Startup:	17,000 lb steam, 150 psig
	May 1996

**Bayshore Regional
Sewerage Authority Union Beach, New Jersey**

**Pete Peterson
732/739-1025**

Reactor:	15'-0" ID, hot windbox design
Feed Rate:	2,250 lb/hr dry solids, sewage sludge
Sludge Characteristics	24 MM btu/hr
Air Pollution Control System	23%TS, 70%VS, 10,000 btu/lbVS
Startup:	Venturi Scrubber, Wet ESP
	December 1995

**Pfizer, Inc.
Groton, Connecticut**
Mike Ritz
860/441-3374

Reactor:
Feed Rate:

Sludge Characteristics
Air Pollution Control System
Startup:

13'-0" ID, hot windbox design
1,520 lb/hr dry biomass solids
15.5 MM btu/hr
27%TS, 75%VS, 10,104 btu/lbVS
Venturi Scrubber, Wet ESP
March 1995

**Longueuil
Quebec, Canada**
Andre Marsan
450/442-1480

Reactor I, II:
Feed Rate:

Sludge Characteristics
Air Pollution Control System
Waste Heat Boiler
Startup:

Each Reactor:
12'-0" ID, hot windbox design
1,800 lb/hr dry solids, sewage sludge
15 MM btu/hr
34%TS, 63%VS, 10,050 btu/lbVS
Dry ESP
11,000 lb steam/hr, 125 psig
August 1992

**Barstow Wastewater
Reclamation Plant, Barstow California**
Rob Derryberry
760/256-2226

Reactor:
Feed Rate:

Sludge Characteristics
Air Pollution Control System
Startup:

7'-0" ID, cold windbox design
430 lb/hr dry solids, sewage sludge
5 MM btu/hr
24%TS, 75%VS, 10,000 btu/lbVS
Venturi Scrubber
July 1992

**City of Juneau WWTP
Juneau, Alaska**
Scott Jeffers
907/586-5329

Reactor:
Feed Rate:

Sludge Characteristics
Air Pollution Control System
Startup:

9'-0" ID, hot windbox design
500 lb/hr dry solids, sewage sludge
7 MM btu/hr
24%TS, 84%VS, 10,000 btu/lbVS
Venturi Scrubber
June 1992

Lynnwood WWTP
Lynnwood, Washington
Don Davis
206/775-1971, Ext. 287

Reactor:	10'-0" ID, hot windbox design
Feed Rate:	850 lb/hr dry solids, sewage sludge
Sludge Characteristics	9.5 MM btu/hr
Air Pollution Control System	25%TS, 82%VS, 10,000 btu/lbVS
Startup:	Venturi Scrubber
	December 1990

Port Washington Water Pollution Control District
Port Washington, New York

Bob Breslin
516/944-6100

Reactor:	9'-6" ID, cold windbox design
Feed Rate:	930 lb/hr dry solids, sewage sludge
Sludge Characteristics	8 MM kcal/hr
Air Pollution Control System	Unknown
Startup:	Venturi Scrubber
	December 1990

Westchester County Sewage Authority
Port Chester, New York

Robert Muriak
914/813-7270

Reactor I, II	Each reactor:
Feed Rate:	12'-0" ID, hot windbox design
Sludge Characteristics	1,125 lb/hr dry solids, sewage sludge
Air Pollution Control System	17.5 MM btu/hr
Startup:	16-25%TS
	Venturi Scrubber
	1990

Northwest Bergen County Utilities Authority
Waldwick, New Jersey

Jack Myer
201/447-2660

Reactor:	14'-0" ID, hot windbox design
Feed Rate:	1900 lb/hr dry solids, sewage sludge
Sludge Characteristics	20 MM btu/hr
Air Pollution Control System	23%TS, 78%VS, 10,000 btu/lbVS
Startup:	Venturi Scrubber
	March 1988

**Gloucester Count Sewage Authority
Thorofare, New Jersey**

Gary Whelan

856/423-3500

Reactor:	11'-0" ID, warm windbox design
Feed Rate:	1,100 lb/hr dry solids, sewage sludge
Sludge Characteristics	17 MM btu/hr
Air Pollution Control System	Unknown
Startup:	Venturi Scrubber
	March 1988

**Camden County Municipal Utilities Authority
Blackwood, New Jersey**

Jack Connolly

856/541-3700

Reactor:	9'-0"ID, hot windbox design
Feed Rate:	816 lb/hr dry solids, sewage sludge
Sludge Characteristics	8 MM btu/hr
Air Pollution Control System	24%TS, 84%VS, 10,000 btu/lbVS
Startup:	Venturi Scrubber
	December 1985

**Allied Chemical Corp / Allied Signal
Detroit, Michigan**

Robert Obrien

313/842-5748

Reactor:	Fluid Bed Boiler-25,000 lbs/hr steam
Feed Rate:	2,243 lb/hr coal tar
Sludge Characteristics	40 MM btu/hr
Air Pollution Control System	100%TS
Startup:	Bagfilter
	March 1985

**Magindag Industry
Oberndorf, Austria**

Herr Weineroiter

Reactor:	16'-0" ID, double dome calciner
Feed Rate:	15,200 lb/hr magnesium carbonate
Startup:	27 MM btu/hr

March 1984

**Confidential
South Africa**

Reactor:	5-0" ID, cold windbox, calciner
Feed Rate:	440 lb/hr "wonderstone"
Startup :	4 MM btu/hr

November 1981